

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 60152129

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

*Date of Issue*

0001--27147107 001

02.11.2020

(day/mo/yr)

**Genehmigungsinhaber *License Holder***

BARAN KABLO A.Ş.  
ÇERKEŞLİ OSB MAH. İMES 9.CAD. NO: 30  
DİLOVASI  
41455 KOCAELİ  
Türkiye

**Fertigungsstätte *Manufacturing Plant***

BARAN KABLO A.Ş.  
ÇERKEŞLİ OSB MAH. İMES 9.CAD. NO: 30  
DİLOVASI  
41455 KOCAELİ  
Türkiye

**Prüfzeichen *Test Mark***



**Geprüft nach *Tested acc. to***

EN 50525-2-11:2011

**Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit  
*License Fee - Unit***

Cable Ordinary duty flexible cables with thermoplastic PVC insulation

Type Designation: H05VV-F 5

Trademark: BARAN KABLO

Number of cores: 2-5

Rated Voltage: 300/500V

Nominal cross-sectional areas: 0,75mm<sup>2</sup>-4,00mm<sup>2</sup>

Maximum conductor operating temperature: 70°C

This certificate replaced R 60124268 0001.

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety

